



TM

**ACOUSTICAL**  
Sound Solutions for Over 40 Years

**SURFACES INC.**

Soundproofing | Acoustics | Noise & Vibration Control



662 CROMWELL AVENUE  
ST. PAUL, MN 55114  
PHONE: 651/645-3601

REPORT OF: NOISE REDUCTION COEFFICIENT TEST

PROJECT: WALL SOUND ABSORBER: 3" PYRAMID

REPORTED TO: Rendered by Manufacturer and Released to:  
Architectural Surfaces Inc./  
Acoustical Surfaces Inc.

DATE: July 20, 1989  
Revised: November 15, 1989

LABORATORY NO: 4143 89-0437-2

P.O. NO: n/a

**INTRODUCTION:**

This report presents the results of a sound absorption test conducted on a 3" Pyramid style wall sound absorber.

Twin City Testing Corporation has been accredited by the U.S. Department of Commerce, National Institute of Standards and Technology (NIST, formally NBS) under their National Voluntary Laboratory Accreditation Program (NVLAP) for conducting this test procedure. This test report may not be used to claim product endorsement by NVLAP or any agency of the U.S. Government.

**TEST RESULTS SUMMARY:**

The NRC of the sample described herein is 1.00.

(see individual frequency values below under TEST RESULTS).

**SPECIMEN IDENTIFICATION:**

Manufacturer: Rendered by Manufacturer and Released to Architectural Surfaces Inc./Acoustical Surfaces Inc.  
Type: 3" Polyurethane Foam  
Style #: Pyramid"  
Size: 3" x 48" x 48"  
Weight: 9.0 lb. (two panels)  
Weight / Area: 0.28 lb. / ft<sup>2</sup>  
Density: 1.13 lb. / ft<sup>3</sup> (nominal 2.0 lb. / ft<sup>3</sup>)

**TEST PROCEDURE:**

The test was conducted in accordance with ASTM: C423(84a) "Sound Absorption and Sound Absorption Coefficients by the Reverberation Room Method." The sample was placed near, but not at the center of a 5300 cubic foot reverberation chamber. Reverberation times of the empty chamber are compared to the reverberation times of the chamber with the specimen installed, to obtain absorption coefficients at the six octave band test frequencies as prescribed by the standard. Absorption coefficients are the fraction of diffuse incident sound absorbed by the specimen. The fraction of absorbed sound is measured in Sabins per square foot of specimen.

The Noise Reduction Coefficient (NRC) is the average coefficients for 250, 500, 1000 and 2000 Hertz. The average is expressed to the nearest integral of 0.05.



TM

# ACOUSTICAL SURFACES INC.

Sound Solutions for Over 40 Years | Soundproofing | Acoustics | Noise & Vibration Control



662 CROMWELL AVENUE  
ST. PAUL, MN 55114  
PHONE: 651/645-3601

## REPORT OF: NOISE REDUCTION COEFFICIENT TEST

LABORATORY NO: 4143 98-0437-2

DATE: July 20, 1989

Revised: November 15, 1989

PAGE: 2

### TEST PROCEDURE (cont'd)

$$a = [(A2 - A1) / S]$$

Where

A= Absorption coefficient of test specimen, Sabins/ft2

A1=Absorption of empty room, Sabins

A2=Absorption of room with specimen, Sabins

S= Surface area, ft2

### TEST EQUIPMENT:

<u>Manufacturer</u>	<u>Model</u>	<u>Description</u>	<u>S/N</u>
Bruel & Kjaer	3347	Real Time Spectrum Analyzer	487013
Bruel & Kjaer	4710	Control & Display Unit	490447
Bruel & Kjaer	3923	Rotating Microphone Boom	263439
Larson - Davis	2560	Pressure Condenser Microphone	1032
Allison Labs	650R	Random Noise Source	1
Allison Labs	2ABR	Variable Cutoff Filter	1061
Commodore	VIC20	Computer	P825447

### TEST RESULTS:

COEFFICIENT			COEFFICIENT		
FREQ	SABINS/FT2	C.L.	FREQ	SABINS/FT2	C.L.
125	0.44	0.80	1000	1.12	0.03
250	0.48	0.02	2000	1.16	0.04
500	1.19	0.02	4000	1.16	0.05

FREQ = Frequency - Octave Band (Hz)

Coefficient = Sound Absorption Coefficient, Sabins / ft2

C.L. = Uncertainty, Sabins / ft2 (95% Confidence Limit)



**twin city testing**  
 corporation

662 CROMWELL AVENUE  
 ST. PAUL, MN 55114  
 PHONE: 651/645-3601

**REPORT OF: SOUND ABSORPTION TEST**

LABORATORY NO: 4143 98-0437-2


DATE: July 20, 1989

Revised: November 15, 1989

PAGE: 3

**TEST RESULTS CONT'D**

Test Conditions: 23.5 C      48% RH      29.80 in HG



**NRC = 1.00**

TWIN CITY TESTING CORPORATION

*Kathryn W. Hatlestad*

Kathryn W. Hatlestad  
 Acoustical/Vibration Engineer  
 Acoustical/Fenestration Dept

Reviewed by:

*Richard O. Thomalla*

Richard O Thomalla  
 Supervisor  
 Acoustical/Fenestration Dept.